





CERTIFICATE

for the
Hygienic qualification of 'OP-RC Ia Plenum Modul'

Contractee	Weiss Umwelttechnik GmbH, Reiskirchen, Germany
Inspected object	Mobile Cleanroom Surgical Tentsystem Type reference: 'OP-RC Ia Plenum-Modul' TKZ: 6230-0020; NSN: 8340-12-388-8421 System manufacturer: M.Schall GmbH & Co. KG, Merzenich-Girbelsrath, Germany Manufacturer Mobile Air Conditioning Systems: Weiss Umwelttechnik GmbH, Reiskirchen, Germany
Inspection	Visual pre-check according to DIN 1946-4:2008-12, Annex B Measurement of protection degree according to DIN 1946-4:2008-12, Annex C
Inspection result	The OP-RC Ia Plenum-Modul meets the protection performance required by DIN 1946-4:2008-12 for class Ia operating rooms. There are no hygienic related objections to put the Mobile Cleanroom Surgical Tentsystem into operation.
Inspection report	32086-OP-ESG-ZELT-0512-A dated 2012-05-21
Date of issue	2012-05-21
Authorisation, signature	Dirk Peltzer, Münster <u>06.06.2012</u> 



Decontamination Construction Consulting Analytics Ventilation and Air-conditioning

HYBETA GmbH - Head Office
Nevinghoff 20 | 48147 Münster
T: +49 (0)251 2851-0 | F: +49 (0)251 2851-129
info@hybeta.com | www.hybeta.com

HYBETA GmbH - Branch Office South
Im Breitspiel 17 | 69126 Heidelberg
T: +49 (0)6221 18588-0 | F: +49 (0)6221 18588-129
info.sued@hybeta.com | www.hybeta.com

HYBETA GmbH - Branch Office East
Am Strengebach 3 | 04509 Krostitz-Hohenossig
T: +49 (0)34294 8452-7 | F: +49 (0)34294 8452-8
info.ost@hybeta.com | www.hybeta.com